

SDEE TS TABEL nr. 6 – Clasificarea cresterilor de tensiune dupa durata si tensiunea pentru anul 2017

C.PRAM Alba

1.Statia Sebes 110/20kV:

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	391	28	4
$120 > u > 110$	251	96	3

2.Statia Turnatorie 110/6kV:

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	344	59	3
$120 > u > 110$	168	121	3

3.Statia Petresti 110/6kV

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	359	35	3
$120 > u > 110$	146	66	5

C.PRAM

Statia 110/20kV Ghimbav: BRASOV

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	2171	505	229
$120 > u > 110$	3678	1890	333

Statia 110/27,5/20/6kV Zizin :

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	187	29	5
$120 > u > 110$	605	75	5

C.PRAM Harghita

1.Statia 110/20 kV Tabara

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	40	54	2
$120 > u > 110$	53	0	0

statie 110/20 kV Miercurea Ciuc

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	82	3	0
$120 > u > 110$	0	0	0

C.PRAM Mures

statie 110/20/6 kV Targu Mures (20 kV)

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	0	0	0
$120 > u > 110$	5	3	0

statie 110/20/6 kV Targu Mures (6 kV)

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	0	0	0
$120 > u > 110$	4	1	0

C.PRAM Sibiu

Statia 110/20 kV A.Vlaicu

Tensiune maxima u %	Durata t ms		
	$10 \leq t \leq 500$	$500 < t \leq 5000$	$5000 < t \leq 60000$
$u \geq 120$	0	1	0
$120 > u > 110$	8	6	3